



Nelsonville, Village of  
PO Box 86  
Nelsonville, WI 54458

Date Reported 08/13/21  
Date Received 07/14/21  
DNR State Cert. 750040280

**2100369-01 3151 Oak Street**

Sampled: 7/14/2021 8:20AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
Alachlor ESA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Alachlor OA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Diaminochlorotriazine	2.58	µg/L	1	0.10	0.10	07/19/21	Beacon ELISA	
Metolachlor ESA	4.27	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Metolachlor OA	0.67	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
NO3+NO2(N)	24.5	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-02 3141 Oak Street**

Sampled: 7/14/2021 8:25AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
Alachlor ESA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Alachlor OA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Diaminochlorotriazine	0.17	µg/L	1	0.10	0.10	07/19/21	Beacon ELISA	
Metolachlor ESA	0.50	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Metolachlor OA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
NO3+NO2(N)	16.1	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-03 3111 Oak Street**

Sampled: 7/14/2021 8:30AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
Alachlor ESA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Alachlor OA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Diaminochlorotriazine	ND	µg/L	1	0.10	0.10	07/19/21	Beacon ELISA	
Metolachlor ESA	0.24	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Metolachlor OA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
NO3+NO2(N)	13.2	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-04 3021 Oak Street**

Sampled: 7/14/2021 8:38AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
NO3+NO2(N)	12.8	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	



**Nelsonville, Village of**

PO Box 86

Nelsonville, WI 54458

Date Reported 08/13/21

Date Received 07/14/21

DNR State Cert. 750040280

**2100369-05 2980 Oak Street**

Sampled: 7/14/2021 8:45AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
Alachlor ESA	0.14	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Alachlor OA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Diaminochlorotriazine	1.07	µg/L	1	0.10	0.10	07/19/21	Beacon ELISA	
Metolachlor ESA	2.98	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Metolachlor OA	0.15	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
NO3+NO2(N)	15.6	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-06 9515 Jerome Street**

Sampled: 7/14/2021 8:13AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
Alachlor ESA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Alachlor OA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Diaminochlorotriazine	0.29	µg/L	1	0.10	0.10	07/19/21	Beacon ELISA	
Metolachlor ESA	0.73	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Metolachlor OA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
NO3+NO2(N)	18.7	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-07 3064 Hwy Q**

Sampled: 7/14/2021 8:51AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
NO3+NO2(N)	15.3	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-08 2920 Hwy Q**

Sampled: 7/14/2021 9:05AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
NO3+NO2(N)	13.2	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-09 3109 High Street**

Sampled: 7/14/2021 9:15AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
NO3+NO2(N)	20.8	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-10 3099 High St**

Sampled: 7/14/2021 10:58AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
Alachlor ESA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Alachlor OA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Diaminochlorotriazine	1.08	µg/L	1	0.10	0.10	07/19/21	Beacon ELISA	
Metolachlor ESA	2.86	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Metolachlor OA	0.27	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
NO3+NO2(N)	20.7	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	



Nelsonville, Village of  
PO Box 86  
Nelsonville, WI 54458

Date Reported 08/13/21  
Date Received 07/14/21  
DNR State Cert. 750040280

**2100369-11 3467 Welton Drive**

Sampled: 7/14/2021 7:00AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
NO3+NO2(N)	8.6	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-12 3453 Welton Drive**

Sampled: 7/14/2021 7:15AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
NO3+NO2(N)	9.4	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-13 3450 Welton Drive**

Sampled: 7/14/2021 7:20AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
Alachlor ESA	1.26	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Alachlor OA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Diaminochlorotriazine	0.13	µg/L	1	0.10	0.10	07/19/21	Beacon ELISA	
Metolachlor ESA	0.47	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Metolachlor OA	0.23	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
NO3+NO2(N)	11.0	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-14 9517 CR-SS**

Sampled: 7/13/2021 11:45AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
Alachlor ESA	0.08	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Alachlor OA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Diaminochlorotriazine	0.23	µg/L	1	0.10	0.10	07/19/21	Beacon ELISA	
Metolachlor ESA	1.57	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Metolachlor OA	0.12	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
NO3+NO2(N)	13.5	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-15 9522 CR-SS**

Sampled: 7/14/2021 7:45AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
Alachlor ESA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Alachlor OA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Diaminochlorotriazine	0.41	µg/L	1	0.10	0.10	07/19/21	Beacon ELISA	
Metolachlor ESA	1.14	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Metolachlor OA	0.13	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
NO3+NO2(N)	9.9	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-16 9527 CR-SS**

Sampled: 7/14/2021 7:50AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
NO3+NO2(N)	11.7	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	



Nelsonville, Village of

PO Box 86

Nelsonville, WI 54458

Date Reported 08/13/21

Date Received 07/14/21

DNR State Cert. 750040280

**2100369-17 9548 CR-SS**

Sampled: 7/14/2021 7:55AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
Alachlor ESA	0.08	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Alachlor OA	ND	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Diaminochlorotriazine	0.42	µg/L	1	0.10	0.10	07/19/21	Beacon ELISA	
Metolachlor ESA	2.00	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
Metolachlor OA	0.14	µg/L	1	0.08	0.08	07/27/21	WEAL LC/MS	
NO3+NO2(N)	14.3	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-18 9418 1st St**

Sampled: 7/14/2021 9:30AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
NO3+NO2(N)	4.1	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-19 9568 CR-SS**

Sampled: 7/14/2021 10:45AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
NO3+NO2(N)	20.2	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**2100369-20 9689 CR-SS**

Sampled: 7/14/2021 10:25AM	Result	Units	Dilution	LOD	LOQ	Analyzed	Method	Notes
NO3+NO2(N)	25.2	mg/L	1	0.1	0.3	07/16/21	SM4500-NO3- F	

**NOTES/DEFINITIONS**

- H: Holding time exceeded
- ND: Analyte not detected at or above the reporting limit
- Q: Quality control failure
- LOD: Limit of Detection
- LOQ: Limit of Quantitation
- INT : Interference in sample

Authorized Signature:

William DeVita