Village of Nelsonville well statistics as of 1/21/21

62%	of wells tested and reported at 10 mg/l or above	36	out of	58
9%	of wells tested and reported between 8 and 9.9 since village testing started	5	out of	58
76%	of wells that have ever been tested and reported over 10 mg/l	44	out of	58
71%	Number of wells that should potentially be replaced (8 and above at some point)	41	and currently in use	

10 mg/l or above		Highest	thru 2021	21-Apr	21-Jan	20-Oct	SP DACT 7/20	DATCP 9/20	DACT 9/20	20-Jul	SP DACT 7/20	20-May	Jan-20	Oct-19	Jul-19	Nov-18	Jul-18
East side of Tomorrow River - recharge is N/NE of village																	
1	9517 CTY SS	14.5	4/3/2021	14.5	13.5	12	0.19			11.2	0.19	12.7	11.9	9.8	12.8	10.4	12.20
2	9522 CTY SS	18.4	11/8/2018	11.8	13.8	17.3	0.54	15.7	1.6134	10.5	0.54	11.1	11.7		10.8 (Jun)	18.4	15.8(May)
3	9527 CTY SS	12.5	1/5/2021	10.9	12.5	11.8	0.58			9.8	0.58	8.4	9.2	10.7	10.3	8.5	
4	9548 CTY SS	15.0	1/5/2021	14.2	15.0	14.9	0.83			13.5	0.83	13.2	12.7		14.6	12.7	12.5(Jun)
5	9568 CTY SS	25.8	4/3/2021	25.8	21.3	15.8				19.2		22.0	20.6	20.4	18.7	16.6	
6	9580 CTY SS	10.0	8/4/2017														
7	9532 CTY SS	13.8	5/14/2004														
8	9610 CTY SS	11.7	11/6/2018												11.5	11.7	
9	9689 CTY SS	28.9	10/7/2020	26.1	27.9	28.9				25.1		20.2	19.1	25.1	23.7	20.7	
10	9699 CTY SS	26.3	4/3/2021	26.3	21.7	21.9	ND			21.1	ND	18.5	19.4	24.9	26.3	23.7	21.4(Jun)
11	2960 OAK	12.0	5/22/2015												9.2	10.4	
12	2980 OAK	15.1	10/7/2020	14.5	14.4	15.1	1.7	14.7	1.9365	14.6	1.7	12.3	10.7	9.4	9.8	12.7	
13	3010 OAK	12.9	11/8/2018													12.9	
14	3021 OAK	14.3	7/6/2019	13.7		11				11.9		11.2	12.2	12.4	14.3	12.6	
15	3101 OAK	15.6	11/5/2018													15.6	
16	3111 OAK	19.1	5/21/2018	18.0	16.0	10.4	ND			9.2	ND	12.8	11.8	13.2	13.0	16.7	19.1(May)
17	3141 OAK	19.4	10/7/2020	16.8	17.2	19.4	0.83			19.3	0.83	18.1	15.6	18.1	18.6	19.2	
18	3151 OAK	25.5	5/6/2020	24.7, .2 RO	21.9, 2 RO	19.4	3.1	20.5	3.0391	22.7,9.4 RO	3.1	25.5,0.9 RO	22.1		13.7	13.8	
19	3099 HIGH ST	17.4	4/3/2020	17.4	12.1	15.9	1.1	16.1	1.8571	16.4	1.1	13.7	13.9,14.06			17.1	
20	3109 HIGH ST	23.9	7/7/2019	20.1											23.9	19.7	
21	3139 HIGH ST	21.3	10/8/2019		7.6	8.2								21.3	6.7	11.6	13(Jun)
22	2920 HWY Q	25.5	1/16/2020	12.9	13.9	12.2				18.2		15.4	25.5			15.3	
23	3040 HWY Q	14.7	11/6/2018													14.7	
24	3078 HWY Q	12.1	11/5/2018													12.1	11.70
25	3064 HWYQ	13.4	4/3/2021	13.4	10.6	7.4				6.6		10.4	7.6	6.2	7.9	8.8	
26	9514 JEROME	17.6	10/8/2019											17.6			16.7(Jun)
27	9515 JEROME	21.9	6/3/2018	20.5	20.3	19.2	0.46			19.4	0.46	17.5,2 RO	18.5			21.0	21.9(Jun)
28	9488 3RD ST	10.4	11/7/2018													10.4	
29	9515 WATER ST	14.0	2/5/2015			9.6										9.2	
West side of Tomorrow River - recharge is from west of residences																	
30	9289 PAVELSKI RD	14.5	5/10/2018												13.3(May)	13.8	14.5(May)
31	3431 WELTON DR	11.6	7/6/2020		11.5	11	0.12			11.6	0.12	11.0	10.7	11.2		11.5	
32	3450 WELTON DR	11.4	7/6/2020							11.4				9.2	10.0	7.9	
33	3453 WELTON DR	11.1	7/6/2020	9.8	9.8	9.8	0.18			11.1	0.18	10.0	10.3	10.9	11.8 ion,10.6	9.5	
34	3467 WELTON DR	10.9	7/7/2019	8.3	7.9	7				6.4		5.8	6.5	8.4	10.9	10.7	
35	3507 WELTON DR	11.3	5/17/2007														
36	3619 ALM RD	10.7	7/17/2007														

Nearing EPA limit

East side of Tomorrow River - recharge is N/NE of village																	
1	3061 OAK	8.8	5/9/2019									7.9			8.8(May)	8.8	
2	3150 OAK	9.6	11/7/2018			8.2										9.6	
3	3089 HIGH ST	8.9	11/6/2018											7.5		8.9	
4	2971 HWY Q	9.3	10/7/2020			9.3										8.6	
West side of Tomorrow River - recharge is from west of residences																	
5	3480 WELTON DR	8.2	11/7/2018											7.6		8.2	

Had been high but got new well

East side of Tomorrow River - recharge is N/NE of village																	
1	9523 CTY SS	9.69 (old	4/6/2001	5.0	6.1	5.6	0.25			5.3	0.25	4.7	5.0	5.7	4.4	4.7	
2	9571 CTY SS	9.2	3/31/1999														

3	3041 OAK	13.4	12/4/2000	8.3	8.0	8.5	0.14	8.0	0.14	8.1	6.9	6.2		3.6		
4	3136 HIGH ST	10.1	9/22/1992										0.9	0.0		
5	2820 HWY Q	15.8	1/13/2015										4.8	4.5	4.5(May)	
6	3090 HWY Q	8.0	5/18/1992							not sure on new well				0.0		
7	9492 1ST ST	16.1	6/21/2006											0.0		0.14
West side of Tomorrow River - recharge is from west of residences																
8	9330 CTY SS	30.0	11/20/2007													0.0
	Have results but they aren't near the EPA limit and/or have never been with the results we have															
East side of Tomorrow River - recharge is N/NE of village																
1	9511 CTY SS	2.0	11/5/2018											2.0		
2	9539 CTY SS	4.3	11/5/2018											4.3		
West side of Tomorrow River - recharge is from west of residences																
3	9387 CTY SS	0.9	5/1/1989										0.1	0.0		
4	9410 CTY SS	5.4	7/7/2019										5.4	5.1		
5	3261 HWY Q	5.9	11/6/2018											5.9		
6	9418 1ST ST	4.6	7/7/2019	4.6		4.3		2.7		1.9	4.0	4.4	4.6	4.4		
7	9439 1ST ST	5.2	11/8/2018											5.2		
8	9299 PAVELSKI RD	1.0	5/5/2005									0.1	0.1	0.0		
9	3415 WELTON DR	4.9	11/6/2018											4.9		